

No. Ka.E/Lo.E.Bem.vi/AE-3/  
2021-22/1523

Office of the Executive Engineer  
Department of Public Works,  
Bangalore Division,

Dated 23.07.2021

To

Veeraparvathi Rathna Educational Trust,  
Harvest International School,  
Innovation Campus, Survey No.2,  
and 3/2, Indlabele Village, Attibele,  
Anekal Taluk, BANGALORE - 562 107.

Sir,


Sub : Regarding issuance Safety Certificate to the building constructed at Survey No.2 & 3/2, Indlabele Village, Attibele Anekal Taluk, Bangalore - 562 107 where Harvest International School Innovation Campus run under Anekal Veeraparvathirathna Educational Trust.

- Ref : 1. Your representation dated 03.05.2021.
2. Letter of the Assistant Executive Engineer Anekal Sub Division, Anekal No. 2021-22/142 dated 22.07.2021.

ATTESTED BEFORE ME  
  
TRUE COPY

With reference to the above subject, through Parvathi rathna Educational Trust, Harvest International School Innovation Campus building is constructed at Survey No.2 & 3/2,



  
CHANCHALA LAKSHMI B.A., LL.B.,  
NOTARY (GOVT. OF INDIA)  
RES. NO. 104, KGF LAYOUT, NEW BEL ROAD,  
DEVASANDRA, BANGALORE - 560 094.  
OFFICE NO. 2, STS COMPLEX, K. YALAPPA BUILDING,  
COURT COMPLEX, ANEKAL, BANGALORE - 562 108.  
www.cci1awchambers.com

Translated From Kannada  
To English  
NOTARY, BANGALORE  
PRINCIPAL  
DEC 2021

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
  
CHAIRMAN

00002 JHNDKANS31M 1259M  
MAY 2021 11:59 AM  
MAY 2021 11:59 AM

Indlabele Village, Attibele, Anekal Taluk, Bangalore - 562 107 the building constructed for the educational purposes, you have sought for issuance of Safety Certificate of the building as per reference No.1 letter above.

Accordingly on 08.06.2021 the Assistant Executive Engineer and Assistant Engineer along with the Secretary of the Harvest International School have inspected the building of Harvest International School Innovation Campus run by Veeraparvathirathna Educational Trust, constructed at Survey No.2 and 3/2, Indlabele Village, Attibele, Anekal Taluk, Bangalore - 562 107 and it is found that building is in good condition.

The building constructed during the year 2020 In the Ground Floor there is parking, in first floor six rooms and one computer lab and one library and further five rest rooms - Urinals for boys and four urinals for girls constructed, in the second floor seven rooms and one staff room, for boys 5 urinals and for girls 5 urinals constructed, in third floor seven rooms are there.

For the safety of the building is concerned we have tested as per Ultrasonic Pulse Velocity Test , it is found that as Per I S Code 456 -2000, IS Code 456-200, IS Code 4926 - 2003, IS Code 516 - 1959 and 8112-1289 for 43 grade, as per the said standards prescribed the concrete beams slabs above A 20 concrete

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
*Deena Devi*  
CHAIRMAN

ATTESTED BEFORE ME  
&  
TRUE COPY



HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
*Deena Devi*  
CHAIRMAN  
CHANCHALA LAKSHMI B.A., LL.B.,  
ADVOCATE & NOTARY (GOVT. OF INDIA)  
Door No.10A, MSE Layout, New BEL Road,  
Devasandra, Bangalore - 560 094.  
Office No. 2, STB Complex, K. Vellappa Building,  
Court Complex, Anekal, Bangalore - 562 106.  
WEBSITE - WWW.CCLAWCHAMBERS.COM

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
*Kannada*  
PRINCIPAL  
Translated from Kannada  
To English  
Correct  
22 DEC 2021  
NOTARY, BANGALORE

capacity is found and the building plan and other documents were submitted for verification.

As regards to the safety of the building, the Assistant Executive Engineer, Anekal Sub Division, Anekal concerning to the concrete capacity as per reference No.2 above, inspections have been made through Karnataka Test House Private Limited, Bangalore, through consultants and Sub Division Technical persons have inspected and as per the report submitted, it is found that the building is constructed well and building is in good condition and accordingly they have reported.

Harvest International School Innovation Campus being run by Veeraparvathirathna Educational Trust, Anekal Taluk, the building is constructed at Survey No.2 and 3/2, Indlabele Village, Attibele, Anekal Taluk, Bangalore - 562 107 and accordingly, the building is constructed in the said place.

The President, Attibele Village Panchayath, Anekal Taluk have approved to put up construction of the building for Harvest International School Innovation Campus, run through Veeraparvathirathna Educational Trust, and the building is constructed at Survey No.2, and 3/2, Indlabelele Village, Attibele, Anekal Taluk, Bangalore

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
*Deena Devi*  
CHAIRMAN

ATTESTED BEFORE ME  
TRUE COPY



HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
*Deena Devi*  
CHAIRMAN  
*22/12/2021*  
CHANCHALA LAKSHMI B.A., LL.B.,  
ADVOCATE & NOTARY (GOVT. OF INDIA)  
Door No.104, KGE Layout, New BEL Road,  
Devasandra, Bangalore - 560 094.  
Office No. 2, STD Complex, K. Yallappa Building,  
Court Complex, Anekal, Bangalore - 562 106.  
WEBSITE: WWW.CCLLAWCHAMBERS.COM

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
*Ratna K*  
PRINCIPAL  
Translated From.....  
To English Verified & Found Correct  
NOTARY, BANGALORE  
22 DEC 2021

00123 JAN 14 2021 10:00 AM  
MAGNIFICATION CHAMBERS  
100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200



The said building is constructed as per the structure plan issued by Keshav and Associates.

### Ultrasonic Pulse Velocity Test

conducting ultrasonic pulse velocity test for compressive strength of in-situ concrete on columns, beams and slab at critical points using PUNDIT '6" (Portable ultrasonic non destructive Digital indicating Tester) equipment form M/s. CNS FARNELL u.k. as per the guidelines in Indian Standards ( IS: 516) (Par 5/sec1): 2018 - the said test has been done by Karnataka Test House Private Limited, Bangalore along with technical squad of the Public Works Department. During the said test it is found that the building is constructed with good quality.

Recognizance, visual inspection for Building settlement in foundation, distress etc., examination is made by Karnataka Test House Private Limited Bangalore with the technical team of the Public Works Department. In the said Test it is found that the building constructed with good quality and of good standard.

The building/as per the guidelines of National Building Code of India 2016, and Sarthak Architecture and Engineering (P) Limited Licence No. B.C.C./BL-3/SE-240/2017-18 consulting structural Engineers have certified and the institution has submitted the same.

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
*Chairman*  
CHAIRMAN



ATTESTED BEFORE ME  
*[Signature]*  
TRUE COPY

CHANCHALA LAKSHMI B.A., LL.B.,  
ADVOCATE & NOTARY (GOVT. OF INDIA)  
Door No. 104, KGF Layout, New BEL Road,  
Devasantra, Bangalore - 560 094.  
Office No. 2, S. B. Complex, K. Yalappa Building,  
Court Complex, Anekal, Bangalore - 562 106.  
WEB SITE: WWW.COLLAWCHAMBERS.COM

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
Translated From *Kannada*  
To English Via *Kathak*  
PRINCIPAL  
NOTARY, BANGALORE

22/12/2021 - DEC 2021

National Building Code of India 2016 and as per them Certificate for Structural Design Sufficiency Certificate is issued by Sarthak Architecture and Engineering (P) Limited, Licence No. B.C.C./BL-3.6/SE240/2017-18 consulting structural Engineers were issued (Annex.C)

National Building Code of India 2016 - as per the same Form for Engagement of Builder/constructor Certificate issued by Sarthak Architecture and Engineering (P) Licence No. B.C.C./BL-3.6/SE-240/2017-18 Consulting Structural Engineers have issued (Annexure D )

On verification of the documents furnished by the said Institution, the Sarthak Architecture and Engineering (P) Licence No. B.C.C./BL-3.6/SE240/2017-18 - consulting structural Engineers have put up construction of the building architecturally by considering the certificate issued by them, and as per the report issued by Technical Team of the Public Works Department, it is found that the building is structurally stable. The undersigned on 22.07.2021 personally inspected the building and has issued the No Objection Certificate that **HARVEST INTERNATIONAL SCHOOL INNOVATION CAMPUS BUILDING is 'STRUCTURALLY STABLE'** and issued the certificate.



Yours faithfully,  
sd  
Executive Engineer,  
PWD, Bangalore Division,  
Bangalore

**HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS**  
*[Signature]*  
**CHAIRMAN**

True Translation from Kannada to English  
*[Signature]*  
**CHANCHALA LAKSHMI B.A., LL.B.,**  
ADVOCATE & NOTARY (GOVT.OF INDIA)  
Door No.104, KGE Layout, New BEL Road,  
Devasandra, Bangalore - 560 094.  
Office No. 2, STB Complex, K. Yallappa Building,  
Court Complex, Anekal, Bangalore - 562 106.  
WEBSITE : WWW.CCLLAWCHAMBERS.COM

**HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS**  
*[Signature]*  
Translated From...  
To English Verified & Found Correct  
**PRINCIPAL**  
**NOTARY, BANGALORE**

MEC 2021



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ

ಸಂಖ್ಯೆ : ಕಾರ್ಯ.ಲೋಕೋಪಯೋಗಿ/ಎಇ-3/2021-22 / 1523

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ ಕಛೇರಿ,  
ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ಬೆಂಗಳೂರು  
ವಿಭಾಗ, ಬೆಂಗಳೂರು. ದಿನಾಂಕ: 23/7/21

ರವರಿಗೆ,

ವೀರಪಾರ್ವತಿರತ್ನ ಎಜುಕೇಷನಲ್ ಟ್ರಸ್ಟ್,  
ಹಾರ್ವೆಸ್ಟ್ ಇಂಟರ್ನ್ಯಾಷನಲ್ ಸ್ಕೂಲ್,  
ಇನೋವೇಷನ್ ಕ್ಯಾಂಪಸ್, ಸರ್ವೆ ನಂ-2 & 3/2,  
ಇಂಡ್ಲಬೆಲೆ ವಿಲೇಜ್, ಅತ್ತಿಬೆಲೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು,  
ಬೆಂಗಳೂರು-562107.

ಮಾನ್ಯರೇ,

ವಿಷಯ:- ಆನೇಕಲ್ ತಾಲ್ಲೂಕು ವೀರಪಾರ್ವತಿರತ್ನ ಎಜುಕೇಷನಲ್ ಟ್ರಸ್ಟ್, ವತಿಯಿಂದ ನಡೆಯುವ ಹಾರ್ವೆಸ್ಟ್ ಇಂಟರ್ನ್ಯಾಷನಲ್ ಸ್ಕೂಲ್ ಇನೋವೇಷನ್ ಕ್ಯಾಂಪಸ್, ಸರ್ವೆ ನಂ- 2 & 3/2, ಇಂಡ್ಲಬೆಲೆ ವಿಲೇಜ್, ಅತ್ತಿಬೆಲೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು-562107 ಇಲ್ಲಿ ಶಾಲೆ ನಡೆಸಲು ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡುವ ಬಗ್ಗೆ.

- ಉಲ್ಲೇಖ:-
1. ತಮ್ಮ ಮನವಿ ದಿನಾಂಕ:- 03.05.2021
  2. ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ಆನೇಕಲ್ ಉಪವಿಭಾಗ, ಆನೇಕಲ್ ರವರ ಪತ್ರ ಸಂಖ್ಯೆ: 2021-22/142 ದಿನಾಂಕ: 22.07.2021

\*\*\*

ಮೇಲಿನ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು ವೀರಪಾರ್ವತಿರತ್ನ ಎಜುಕೇಷನಲ್ ಟ್ರಸ್ಟ್, ವತಿಯಿಂದ ನಡೆಯುವ ಹಾರ್ವೆಸ್ಟ್ ಇಂಟರ್ನ್ಯಾಷನಲ್ ಸ್ಕೂಲ್ ಇನೋವೇಷನ್ ಕ್ಯಾಂಪಸ್, ಸರ್ವೆ ನಂ- 2 & 3/2, ಇಂಡ್ಲಬೆಲೆ ವಿಲೇಜ್, ಅತ್ತಿಬೆಲೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು-562107, ಇಲ್ಲಿನ ಕಟ್ಟಡದ ಶೈಕ್ಷಣಿಕ ಉದ್ದೇಶಕ್ಕಾಗಿ ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡಲು ಉಲ್ಲೇಖ (1) ರ ಪತ್ರದಲ್ಲಿ ಕೋರಿರುತ್ತೀರಿ.

ಅದರಂತೆ ದಿನಾಂಕ: 08.06.2021 ರಂದು ಆನೇಕಲ್ ತಾಲ್ಲೂಕು ವೀರಪಾರ್ವತಿರತ್ನ ಎಜುಕೇಷನಲ್ ಟ್ರಸ್ಟ್, ವತಿಯಿಂದ ನಡೆಯುವ ಹಾರ್ವೆಸ್ಟ್ ಇಂಟರ್ನ್ಯಾಷನಲ್ ಸ್ಕೂಲ್ ಇನೋವೇಷನ್ ಕ್ಯಾಂಪಸ್, ಸರ್ವೆ ನಂ- 2 & 3/2, ಇಂಡ್ಲಬೆಲೆ ವಿಲೇಜ್, ಅತ್ತಿಬೆಲೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು-562107, ಕಟ್ಟಡವನ್ನು ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು ಮತ್ತು ಸಹಾಯಕ ಇಂಜಿನಿಯರ್ ಹಾಗೂ ಹಾರ್ವೆಸ್ಟ್ ಇಂಟರ್ನ್ಯಾಷನಲ್ ಸ್ಕೂಲ್‌ನ ಕಾರ್ಯದರ್ಶಿ ರವರ ಉಪಸ್ಥಿತಿಯಲ್ಲಿ ಕಟ್ಟಡ ಪರಿವೀಕ್ಷಣೆ ಕೈಗೊಂಡು, ಕಟ್ಟಡವು ಸುಸ್ಥಿತಿಯಲ್ಲಿರುವುದನ್ನು ಗಮನಿಸಲಾಗಿರುತ್ತದೆ.

ಕಟ್ಟಡವು 2020 ಇಸವಿಯಲ್ಲಿ ನಿರ್ಮಾಣಗೊಂಡಿದ್ದು, ನೆಲಮಹಡಿಯಲ್ಲಿ ಪಾರ್ಕಿಂಗ್, ಮೊದಲನೇ ಮಹಡಿಯಲ್ಲಿ ಆರು ಕೊಠಡಿಗಳು, ಒಂದು ಕಂಪ್ಯೂಟರ್ ಲ್ಯಾಬ್, ಒಂದು ಲೈಬ್ರರಿ ಹಾಗೂ ಗಂಡುಮಕ್ಕಳಿಗೆ ಐದು ಶೌಚಾಲಯ ಹಾಗೂ ನಾಲ್ಕು ಯೂರಿನ್ ಮತ್ತು ಹೆಣ್ಣು ಮಕ್ಕಳಿಗೆ ಐದು ಶೌಚಾಲಯಗಳಿದ್ದು, ಎರಡನೇ ಮಹಡಿಯಲ್ಲಿ ಏಳು ಕೊಠಡಿಗಳು ಹಾಗೂ ಸ್ಟಾಫ್ ರೂಂ, ಗಂಡುಮಕ್ಕಳಿಗೆ ಐದು ಶೌಚಾಲಯ ಮತ್ತು ಹೆಣ್ಣು ಮಕ್ಕಳಿಗೆ ಐದು ಶೌಚಾಲಯಗಳಿದ್ದು, ಮೂರನೇ ಮಹಡಿಯಲ್ಲಿ ಏಳು ಕೊಠಡಿಗಳು ಇರುತ್ತದೆ.

ಕಟ್ಟಡದ ಸುರಕ್ಷತೆಗೆ ಸಂಬಂಧಿಸಿದಂತೆ ಕಟ್ಟಡವನ್ನು ULTRASONIC PULSE VELOCITY TEST ಮೂಲಕ ಪರೀಕ್ಷಿಸಿ ಕಟ್ಟಡವು IS Code:456-2000, IS Code:456-2000, IS Code:4926-2003, IS Code:516-1959 and 8112-1989 for 43 grade ನಲ್ಲಿ ನಿಗದಿಪಡಿಸಿರುವ ಮಾನದಂಡದಂತೆ ಕಟ್ಟಡದ ಕಾಂಕ್ರೀಟ್ ಕಂಬಗಳು (Columns) ತೊಲೆಗಳನ್ನು (Beams) ಮತ್ತು ಛಾವಣಿಯ (Slab) ವಿನ್ಯಾಸದಂತೆ ಎಂ-20 ಕಾಂಕ್ರೀಟ್ ನ ಸಾಮರ್ಥ್ಯಕ್ಕಿಂತ ಹೆಚ್ಚು ಹೊಂದಿರುವುದಾಗಿ ಕಂಡುಬಂದಿರುತ್ತದೆ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದ ವಿನ್ಯಾಸಗಳ ದಾಖಲೆಗಳನ್ನು ಒದಗಿಸಿರುತ್ತಾರೆ.

ಮುಂದುವರೆದು ಕಟ್ಟಡದ ಸುರಕ್ಷತೆಗೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು (2)ರ ಪತ್ರದಲ್ಲಿ ಕಟ್ಟಡದ ಕಾಂಕ್ರೀಟ್ ಸುಸ್ಥಿತಿಯ ಬಗ್ಗೆ ಕಿರಿಯಾಟಾಲ್ ವೆಸ್ಟ್ ಹೌಸ್ Pvc. L. ಇಂಟರ್ನ್ಯಾಷನಲ್ ಶಾಲೆಯ ಅಭಿಯಂತರ ಪರೀಕ್ಷೆಗಳನ್ನು ಕೈಗೊಂಡು ಸಮಾಲೋಚಿಸಿರಲಾಗಿದೆ ಉಪವಿಭಾಗದ ತಾಂತ್ರಿಕ

**HARVEST INTERNATIONAL SCHOOL**  
Pvc. L. INNOVATION CAMPUS  
  
**CHAIRMAN**


**HARVEST INTERNATIONAL SCHOOL**  
Karnataka West House  
INNOVATION CAMPUS  
  
**PRINCIPAL**



- ಆನೇಕಲ್ ತಾಲ್ಲೂಕು, ವೀರಪಾರ್ವತಿರತ್ನ ಎಜುಕೇಷನಲ್ ಟ್ರಸ್ಟ್, ವತಿಯಿಂದ ಪಡೆಯುವ ಹಾರ್ವೆಸ್ಟ್ ಇನ್ಟರ್ನ್ಯಾಷನಲ್ ಸ್ಕೂಲ್ ಇನ್ಟೋವೇಷನ್ ಕ್ಯಾಂಪಸ್, ಸರ್ವೆ ನಂ- 2 & 3/2, ಇಂಡ್ಲಬೆಲೆ ವಿಲೇಜ್, ಅತ್ತಿಬೆಲೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು-562107, ಇಲ್ಲಿ ನಿರ್ಮಿಸಲಾಗಿರುವುದಾಗಿ ತಿಳಿಸಿರುತ್ತಾರೆ. ಅದರಂತೆ, ಕಟ್ಟಡವನ್ನು ಸದರಿ ಸ್ಥಳದಲ್ಲಿ ನಿರ್ಮಿಸಲಾಗಿರುತ್ತದೆ.
- ಅಧ್ಯಕ್ಷರು, ಅತ್ತಿಬೆಲೆ ಗ್ರಾಮ ಪಂಚಾಯಿತಿ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು ರವರಿಂದ ಅನುಮೋದನೆಯಾದ ವೀರಪಾರ್ವತಿರತ್ನ ಎಜುಕೇಷನಲ್ ಟ್ರಸ್ಟ್, ವತಿಯಿಂದ ನಡೆಯುವ ಹಾರ್ವೆಸ್ಟ್ ಇನ್ಟರ್ನ್ಯಾಷನಲ್ ಸ್ಕೂಲ್ ಇನ್ಟೋವೇಷನ್ ಕ್ಯಾಂಪಸ್, ಸರ್ವೆ ನಂ-2 & 3/2, ಇಂಡ್ಲಬೆಲೆ ವಿಲೇಜ್, ಅತ್ತಿಬೆಲೆ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು-562107, ಕಟ್ಟಡವನ್ನು ನಿರ್ಮಿಸಲಾಗಿರುತ್ತದೆ.
- ಸದರಿ ಕಟ್ಟಡವನ್ನು Keshav and Associates ಸಂಸ್ಥೆ ರವರು ನೀಡಿರುವ ಸ್ಪಷ್ಟರಲ್ ಏನ್ಯಾಸದಂತೆ ನಿರ್ಮಿಸಲಾಗಿರುತ್ತದೆ.
- Ultrasonic Pulse Velocity Test  
Conducting Ultrasonic pulse velocity test for compressive strength of in-situ concrete on Columns, Beams and Slab at Critical points using "PUNDIT 6" (Portable ultrasonic non-destructive Digital indicating Tester) equipment form M/s. CNS FARNELL u.k as per the guidelines in Indian standards (IS:516 (Par 5/Sec 1): 2018) ಪರೀಕ್ಷೆಯನ್ನು, Karnataka Test House Pvt. Ltd Bangalore ರವರ ಜೊತೆ ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆಯ ತಾಂತ್ರಿಕ ತಂಡದೊಂದಿಗೆ ಕೈಗೊಳ್ಳಲಾಗಿರುತ್ತದೆ. ಸದರಿ ಪರೀಕ್ಷೆಯಲ್ಲಿ ಕಟ್ಟಡವು ಉತ್ತಮ ಗುಣಮಟ್ಟದಿಂದ ಕೂಡಿರುವುದು ಕಂಡುಬಂದಿರುತ್ತದೆ.
- Recognizance, visual inspection fo Building settlement in foundation, distress etc. ಪರೀಕ್ಷೆಯನ್ನು Karnataka Test House Pvt. Ltd Bangalore ರವರ ಜೊತೆ ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆಯ ತಾಂತ್ರಿಕ ತಂಡದೊಂದಿಗೆ ಕೈಗೊಳ್ಳಲಾಗಿರುತ್ತದೆ. ಸದರಿ ಪರೀಕ್ಷೆಯಲ್ಲಿ ಕಟ್ಟಡವು ಉತ್ತಮ ಗುಣಮಟ್ಟದಿಂದ ಕೂಡಿರುವುದು ಕಂಡುಬಂದಿರುತ್ತದೆ.
- ಕಟ್ಟಡವು National Building code of India 2016 ರ ಮಾನದಂಡದಂತೆ ನಿರ್ಮಿಸಿ ಸುರಕ್ಷಿತವಾಗಿರುವುದಾಗಿ Sarthak Architecture and Engineering (P) , Licence No.B.C.C/BL-3.6/SE-240/2017-18 Consulting Structural Engineers ರವರು ದೃಢೀಕರಿಸಿ ನೀಡಿರುವ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಸಂಸ್ಥೆಯವರು ಓದಗಿಸಿರುತ್ತಾರೆ.
- National Building code of India 2016 ರ ಅನ್ವಯ Certificate for Structural Design Sufficiency ಪ್ರಮಾಣ ಪತ್ರವನ್ನು Sarthak Architecture and Engineering (P), Licence No.B.C.C/BL-3.6/SE-240/2017-18 Consulting Structural Engineers ರವರು ನೀಡಿರುತ್ತಾರೆ. (Annex-C)
- National Building code of India 2016 ರ ಅನ್ವಯ Form for Engagement of Builder / Constructor ಪ್ರಮಾಣ ಪತ್ರವನ್ನು Sarthak Architecture and Engineering (P), Licence No.B.C.C/BL-3.6/SE-240/2017-18 Consulting Structural Engineers ರವರು ನೀಡಿರುತ್ತಾರೆ. (Annex-D)

ಸದರಿ ಸಂಸ್ಥೆಯವರು ನೀಡಿರುವ ಎಲ್ಲಾ ದಾಖಲೆಗಳನ್ನು ಪರಿಶೀಲಿಸಲಾಗಿ Sarthak Architecture and Engineering (P), Licence No.B.C.C/BL-3.6/SE-240/2017-18 Consulting Structural Engineers ರವರು ಕಟ್ಟಡವು ರಚನಾತ್ಮಕವಾಗಿ ಸುರಕ್ಷಿತವಾಗಿದೆಯೆಂದು ನೀಡಿರುವ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಪರಿಗಣಿಸಿ, ಹಾಗೂ ಕಟ್ಟಡವನ್ನು ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆಯ ತಾಂತ್ರಿಕ ತಂಡ ನೀಡಿರುವ ವರದಿಯಂತೆ ಕಟ್ಟಡವು "Structurally Stable" ಇರುವುದಾಗಿ ಪರಿಶೀಲನೆಗಳಿಂದ ಕಂಡುಬಂದಿರುವುದರಿಂದ, ಈ ಕೆಳ ಸಹಿ ಮಾಡಿರುವವರು ದಿನಾಂಕ: 22.07.2021 ರಂದು ಖುದ್ದಾಗಿ ಪರೀಕ್ಷಿಸಿ HARVEST INTERNATIONAL SCHOOL INNOVATION CAMPUS ಕಟ್ಟಡವು "Structurally Stable" ಇದೆ ಎಂದು ನಿರಾಕ್ಷೇಪಣಾ ಪತ್ರವನ್ನು ನೀಡಲಾಗಿದೆ.

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
  
CHAIRMAN

ತಮ್ಮ ವಿಶ್ವಾಸಿ,  
  
ಕಾರ್ಯವಾಹಕ ಅಭಿಯಂತರರು,  
ಲೋಕ, ಬೆಂಗಳೂರು ವಿಭಾಗ,  
ಬೆಂಗಳೂರು.

HARVEST INTERNATIONAL SCHOOL  
INNOVATION CAMPUS  
  
PRINCIPAL